



ACCELERATED OPEN INVITATION TO TENDER
AO/DRS/ASAIN/Windows/003/16
Renovation of facades at the Cedefop building
Request for Clarification (2) – Questions & Answers

Question No 1

In which laboratory will the testing, foreseen in point 2.2.7, take place?

Cedefop's answer to question No 1

In accordance with point 2.2.7 of the tender documents, both mock up and installation testing will be carried out at Cedefop premises. In both cases, the system(s) will be tested against water penetration and air infiltration.